



## CERTIFICATE

This is to certify that  
Elevator Guide Rails T90/B  
Meets Quality Standards

ISO7465: 2007 (Guide Rail Standard)  
YB/T157-1999(Raw Material Standard)

### Chemical Composition

	C%	Mn%	P%	S%	Si%
Standard	$\leq 0.2$	$\leq 1.4$	$\leq 0.045$	$\leq 0.045$	$\leq 0.35$
Dimensional Data	0.17	0.52	0.031	0.017	0.15

### Mechanical Test

	Rel N mm <sup>2</sup> the yeid strength	Breaking Point N/mm <sup>2</sup>	Elongation
Standard	$\geq 235$	375~500	$\geq 24\%$
Dimensional Data	255	455N/mm <sup>2</sup>	35%

1.The mechanical properties are compliance to ISO standard.

马拉兹(江苏)电梯导轨有限公司  
Quality Assurance  
MARAZZI(JIANGSU)ELEVATOR GUIDE RAIL CO.,LTD

2019-8-28